

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair
Observed burnt-out light bulbs in the following rooms: 003, 007, 008, 009, 014, 016, 018. Replace burnt-out light bulbs.
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #9. Mechanical Ventilation
Observed out of order exhaust vent in girl's bathroom 018. Repair exhaust vent.
CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

Violation #11. Group Toilet Rooms
Observed out of order urinal in boy's bathroom 210. Repair or replace out of order urinal.
CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #22. First Aid Kit
Observed the following expired items in the first aid kit:

Sterile water for irrigation 08/2021
Alcohol prep pads 09/2022

Discard expired items. PIC discarded expired items (COS).
CODE REFERENCE: 22. First Aid Kit. 5(11)(i) SREF. First aid kits shall be fully equipped per Board policy 5(1)(e)10 and available for student use.

Inspection Conducted By: Raad Farhang (913251)
Inspector Contact Number: Work: (305) 623-3575 ex.
Print Client Name:
Date: 11/17/2023

Inspector Signature:

Handwritten signature of Raad Farhang.

Client Signature:

Handwritten signature of the client.